

## 試驗報告



報告編號：HV-14-01983X

頁數：1 OF 1

報告日期：103年04月16日

委託單位：旺乘企業有限公司  
地址：桃園市民生路668之4號  
供應廠商：利乘 LISTEN  
樣品名稱：利乘壓接管件(雙卡)  
送驗人員：旺乘企業有限公司(林銘輝)  
收件日期：103年03月17日  
試驗日期：103年03月17日~103年04月14日  
備註：以上資料由顧客提供(收件及試驗日期除外)

### 試驗結果：

樣品名稱：利乘壓接管件(雙卡)

試驗項目	試驗方法	試驗結果
水壓試驗(40kgf/cm <sup>2</sup> ，2分鐘)	參考 CNS 14645(2002)	無洩漏現象
拔出阻力(kgf)	註.	221

註：依顧客指定方式，施加壓力至 2 kgf/cm<sup>2</sup>，以 2mm/min 速率執行拉伸至洩漏為止。

----- o o o -----

規範要求值僅供參考，合格之判定以委託單位實際要求為準。

高偉明  
報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

Laboratory Testing · ISO Certification · Inspection

No.35, Wu Chyuan Road  
WuKu Industrial Zone,  
Taipei County, Taiwan  
Tel: (886-2) 2298-3355  
Fax: (886-2)2298-3880


REPORT NO.: HV-14-01983X



NO.1



NO.2



NO.3



NO.4

----- oOo -----



## 試驗報告



報告編號：HV-14-01382X

頁數：1 OF 1

報告日期：103年04月16日

委託單位：旺乘企業有限公司  
地址：桃園市民生路 668 之 4 號  
供應廠商：利乘 LISTEN  
樣品名稱：利乘壓接管件(單卡)  
送驗人員：旺乘企業有限公司(林銘輝)  
收件日期：103年03月17日  
試驗日期：103年03月17日~103年04月14日  
備註：以上資料由顧客提供(收件及試驗日期除外)

### 試驗結果：

樣品名稱：利乘壓接管件(單卡)

試驗項目	試驗方法	試驗結果
水壓試驗(30kgf/cm <sup>2</sup> ，2分鐘)	參考 CNS 14645(2002)	無洩漏現象
拔出阻力(kgf)	註.	250

註：依顧客指定方式，施加壓力至 2 kgf/cm<sup>2</sup>，以 2mm/min 速率執行拉伸至洩漏為止。

----- o O o -----

規範要求值僅供參考，合格之判定以委託單位實際要求為準。

  
報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.